

eco-INSTITUT, Schanzenstr. 6-20, Carlswerk 1.19, D-51063 Köln

Hilti Entwicklungsgesellschaft mbH
Hiltistrasse 6
86916 Kaufering

Dear Sirs / Madames,

based on the evaluation of Test report **60069-A001-AgBB-L** dated **31/07/2025**, for the product **CFS-CT B**, commissioned by **Hilti Entwicklungsgesellschaft mbH**, we confirm compliance with the requirements of:

- VOC product emissions acc. to DIN EN 16516:2020-10 and LCI values from Table 1 of the AgBB Scheme 2024 after 28 days

These criteria meet the requirements for low-emitting **Insulation** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System for projects outside the US.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Loading factor	Individual VOCs of Concern		Formaldehyde		TVOC (EN 16516)
	Requirement	Requirement hold	Requirement	Requirement hold	
0.05 m ² /m ³ for small areas	< LCI	yes	≤ 10 µg/m ³	yes	> 0.5 mg/m ³

Mass per surface area: not applicable

Cologne, 31/07/2025



Marc-Anton Dobaj, M.Sc. Crystalline Materials
(Project management)